
NET-A-11026 - AERIAL VIEW



NET-A-11026 – SOUTHEAST STREET VIEW



ComEd AMI Project WO#: 17057995-36



EXAMPLE OF TRANSFORMER



EXAMPLE OF PEDESTAL



Proposed splice pit. Coogle

NET-A-11026 – SOUTHEAST STREET VIEW

	Permit Type	Project Name	Office	Designer	Locatior
AMI RELAY ID: MPR476072A2	**SEE TABLE	0000297970	CRESTWOOD	JANET CHERIAN	WATERG
	Permit Number	SR #	JWA #	Phone #	
FEEDER MAP: 12 KV D9312 (PAGE# 7 OF 7)	PENDING	05120198	N/A	(312)763-2198	
	Joint Work Contact	SER/CWA #	Phone RO #	PD #	Town or
*LABEL PER C7493	N/A	N/A	N/A	N/A	WILLOW
*MAINTAIN CLEARANCE PER C7500, C5285 **CITY(WILLOW SPRINGS) & PALOS TOWNSHIP	Date Issued: 2021.05.0		Contingent WO #s	N/A	Complet
RD, COOK COUNTY FOREST PRESERVE	0.0	50.0 100.0 FT		Page 1 of 1	Verified
LOCATION 1: SPLICE PIT (41.711332, -87.897410) -REMOVE CONCRETE COVER -DIG SPLICE PIT -REPLACE EXISTING JOINT WITH 2-STRAIGHT JOINTS PER C6038.AE LOCATION 2: CABLE 1-3 -DIRECT BURY PROPOSED 2/C- #2 AL EXCcJ PRIMARY CABLE BETWEEN LOCATION 1 AND 3 LOCATION 3: TRANSFORMER #476072A2 (41.711288, -87.897409) -INSTALL NEW 25 KVA TRANSFORMER PER C5318.A0A -INSTALL NEW 25 KVA TRANSFORMER PER C5318.A0A -INSTALL AMI RELAY PER C9925.0S ON A NEW COMED 3-PHASE SERVICE PEDESTAL PER C5283.D -INSTALL 2/C #6 AAC UG STREET LIGHT CABLE TO NEW PEDESTAL APPROXIMATELY 5' EAST OF TRF #476072A2	QT 476	W 95TH ST APPROX. 183 R SEC 5072 PRESERVE LOT*			
*CALL JULIE 1-800-892-0123 PRIOR TO DIGGING *CONSTRUCTION TO CONFIRM THE RECEIPT OF PERMITS PRIOR TO STARTING WORK. COPIES OF ALL REQUIRED PERMITS SHALL BE ON JOB SITE AT ALL TIMES.				1	
KDM CONTACT INFO: MATEO ALVARADO MALVARADO@KDMENGINEERING.COM 312-763-2198 EXT 2007 **WORK MAY REQUIRE COORDINATION WITH CUSTOMER TO ACCESS EXISTING CONDUIT	600' 4" PVC 1/c 2	EXCCJ	PROPOSED #2 AL- EXCc. PRIMARY		15'
		4 FIA		6072A2 25-B 3	

